



# GWYTHER MUSICORUM

PAT testing carried out on 4th January 2017.

Visual inspection of equipment and mechanical parts and electrical portable appliance testing.

In compliance with The Electricity at Work Regulations 1989

Equipment	Visual test	Earth Bond	Insulation mohm	Earth Leakage Ma	Notes
08/01/17 1 IEC cable 240 Pass	-	0.025	>50	0	
08/01/17 2 IEC cable 240 Pass	-	0.064	>50	0	
08/01/17 3 IEC cable 240 Pass	-	0.067	>50	0	
08/01/17 4 IEC cable 240 Pass	-	0.029	>50	0	
08/01/17 5 IEC cable 240 Pass	-	0.021	>50	0	
08/01/17 6 IEC cable 240 Pass	-	0.054	>50	0	
08/01/17 7 vv power adapter 240 Pass	-	0.078	>50	0	
08/01/17 8 vv power adapter 240 Pass	-	0.084	>50	0	
08/01/17 9 vv power adapter 240 Pass	-	0.075	>50	0	
08/01/17 10 vv power adapter 240 Pass	-	0.079	>50	0	
08/01/17 11 Laptop power adapter 240 Pass	-	0.065	>50	0	
08/01/17 12 Laptop power adapter 240 Pass	-	0.045	>50	0	
08/01/17 13 4-way extension 240 Pass	-	0.012	>50	0	
08/01/17 14 4-way extension 240 Pass	-	0.074	>50	0	
08/01/17 15 4-way extension 240 Pass	-	0.025	>50	0	
08/01/17 16 6-way extension 240 Pass	-	0.026	>50	0	
08/01/17 17 6-way extension 240 Pass	-	0.021	>50	0	
08/01/17 18 2-way extension 240 Pass	-	0.034	>50	0	
08/01/17 19 Stereo power amp 240 Pass	-	0.056	>50	0	
08/01/17 20 Behringer 6:2 line mixer 240 Pass	-	0.064	>50	0	
08/01/17 21 Behringer 20:2 mixing console 240 Pass	-	0.078	>50	0	
08/01/17 22Rhodes digital piano 240 Pass	-	0.084	>50	0	